

Type test Certificate of complete type tests

Goknur Baki Kabel

Baki, Azerbaijan

has successfully passed the type test sequence on a

single-core power cable

Type: NA2XS2Y

Rating: 18/30(36) kV – 1x 240 mm² – Al – XLPE

The test object passed the required clauses of


IEC 60502-2

The test results are recorded in Certificate No.

TIC 1040-14

This Certificate is issued on 15 October 2014

KEMA Nederland B.V.



S.A.M. Verhoeven

Director Testing, Inspections & Certification The Netherlands

Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.

